

**SUPPLY AND DELIVERY OF MAJOR WTP EQUIPMENT
FOR THE VILLAGE OF LYTTON**

PAGE 1 OF 1
ADDENDUM # 2

Issued: FEBRUARY 24, 2017

- 1.0 PRECEDENCE** .1 This addendum, Addendum #2, shall be read in conjunction with all “Supply And Delivery Of Major WTP Equipment For The Village Of Lytton” Tender and Contract Documents. Where conflicts or discrepancies between those, or other documents, and this addendum arise, this addendum shall take precedence.
- 2.0 SCOPE** .1 Addendum #2 is issued to withdraw the requirement for a Bid Bond and to adjust the number and diameters of the flow meters required.
- .2 Addendum #2 comprises one page.
- 3.0 INSTRUCTIONS** .1 Sign and date the last page of this addendum where indicated.
- .2 Return this addendum with the tender submission.
- 4.0 BONDING REQUIREMENTS** .1 Further to Section 00100 Tender Solicitation, Clause 1.5 Bonding Requirements, delete Clause 1.5.1. A Bid Bond is not required.
- .2 Further to Section 00410 Offer, Item .3, delete this Item and replace with the following:
- .3 The tender shall be accompanied by an Undertaking of Surety duly completed by a guaranty company authorized to carry on business in the Province of British Columbia.
- 5.0 FLOWMETERS** .1 Delete Section 16996 Instrumentation, Clause 2.1.1 and replace with the following:
- 2.1.1 Three (3) 100 mm and one (1) 150 mm flowmeters shall be supplied.
- 7.0 TENDER CLOSING** .1 The tender closing date and time remain unchanged by this Addendum.
- .2 Return tenders no later than 2:00 PM local time on Wednesday, 1st March 2017

Addendum No. 2 received.

Name of Tenderer (please print)

Signature of Tenderer

**** END ADDENDUM #2 ****